

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. DL/KSN/JULY/07

Dated: 30/07/2026

It is certified that an inspection team headed by Neeraj Kumar (A.E)

(Name of Officers with designation) from U.P. Jal Nigam (Rural) Kushinagar PHED

inspected the BBK Academy Vill- Gaziipura, Tamkharaj, Kushinagar

(Name & Address of the school) on 30/07/2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing no. DL/KSN/JULY/07 dated 30/07/2026

of District Water Testing Lab U.P.T.N(R) Kushinagar (PHED Lab) certified that the BBK Academy Vill- Gaziipura Tamkharaj, Kushinagar (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 1 Year

Signature with Seal: सहायक अभियन्ता

Name : Neeraj Kumar

Designation : A.E

Name & Address of the Office / Department : U.P.T.N(R) Kushinagar

To BBK Academy Vill- Gaziipura
Tamkharaj, Kushinagar
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



**District Level Water analysis Laboratory,
Uttar Pradesh Jal Nigam (Rural), Kushinagar
Add. -Vill Parsauni Kala Near Water Tank Padrauna
KUSHINAGAR 274304**

BACTERIOLOGICAL SAMPLE TEST REPORT

Report No.	DL/KSN/ JULY/07	Date	30.07.2026	Page No.	01	
Customer Details						
Name and Address		B.B.K. ACADEMY VILL- GAZIPUR, TAMKUHIRAJ, KUSHINAGAR				
Ref. letter No & Date		NA				
Basic details of sample						
District	KUSHINAGAR	Block	TAMKUHIRAJ			
Gram/Panchayat	GAZIPUR	Village	GAZIPUR			
Habitation	GAZIPUR	Location	NEAR HANUMAN MANDIR			
Water Source	RO WATER SAMPLE	Sample Id	KSN-07			
Quantity of Sample	1000ml	Date of S.C	27.07.2026			
Receiving Date	27.07.2026	S. Collector	ANKIT SINGH			
Sample Depositor	ANKIT SINGH	Analysis Completion Date	30.07.2026			
Analysis Start Date	07.07.2026	Relative Humidity	50-15%			
Temperature- 25±3°C		Technical Data of Analysis				
S. No.	Analyzed Parameters(Unit of Measurement)	Observed Value	Specified Values As per BIS 10500:2012			Ref. Method of Analysis
			Unit	Acceptable Limit	Permissible Limit	
1	pH	7.0	...	6.5	8.5	IS 3035(Part 11): 2022
2	Residual Chlorine	0	mg/L	0.2	1.0	IS 3035(Part 26): 1986
3	Total Coliforms	0	CFU	0	CFU	APIA 23 Edition : 2017
4	E-Coli	0	CFU	0	CFU	APIA 23 Edition : 2017

EDL- Below Detection Limit, NA- Not Analyzed.
* Parameter(s) above permissible limit are in bold I digits.

Note: 1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract.
3. The test results reported in this certificate are valid at the time of under the stated conditions of measurements.
4. Sample will be stored up to 07 days (in case of non-perishable item only) from the date of issue of test reports.
5* Parameter Are Not NABL accredited

Prepared by *Manish*
Reviewed By *chandan*

Authorized Signatory
Contact No-9126706093





**District Level Water analysis Laboratory,
Uttar Pradesh Jal Nigam (Rural), Kushinagar
Add. -VillParsauni Kala Near Water Tank Padrauna
KUSHINAGAR 274304**

Analysis Report						
Report No	DL/KSN/ JULY/07		Date	30.07.2026	Page No	01
Customer Details						
Name and Address	B.B.K. ACADEMY VILL.-GAZIPUR, TANAKUHIRAJ, KUSHINAGAR					
Ref Letter No & Date	NA					
Basic details of sample						
District	KUSHINAGAR	Block	TANAKUHIRAJ			
Gram Panchayat	GAZIPUR	Village	GAZIPUR			
Habitation	GAZIPUR	Location	NEAR HANUMAN MANDIR			
Water Source	RO WATER SAMPLE		Sample Id	KSN_07		
Quantity of Sample	1000ml		Date of S.C.	27.07.2026		
Receiving Date	27.07.2026		S. Collector	ANKIT SINGH		
Sample Depositor	ANKIT SINGH		Analysis Completion Date	30.07.2026		
Analysis Start Date	30.07.2026		Relative Humidity	50±15%		
Temperature- 25±3°C						
Technical Data of Analysis						
S. No.	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values As per BIS 10500:2012			Ref. Method of Analysis
			Unit	Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	
1	pH	6.10	mg/L	5.00	20.00	IS 3025(Part 60) 2022
2	Alkalinity	1628	mg/L	5.00	50.00	IS 3025(Part 34) 2022
3	Hardness	1584	mg/L	5.00	50.00	IS 3025(Part 24) 2022
4	Calcium	0.00	mg/L	0.50	5.00	IS 3025(Part 53) 2022
5	Magnesium	0.00	mg/L	0.005	2.00	IS 3025(BY AAS) 2022
6	Conductivity		(Ms/cm)	NA	NA	IS 3025(Part 10) 2017
#BDL- Below Detection Limit, NA- Not Analyzed.						
** Parameter(s) above permissible limit are in bold digits.						
Note: 1. This Certificate refers only to the particular sample(s) submitted for testing.						
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract.						
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.						
4. Sample will be stored up to 07 days (in case of non-perishable item only) from the date of issue of test report.						
5* Parameter are not NABL accredited						
Prepared by Manish Email: 111ubhulsnagar@gmail.com Reviewed By chandan Authorized Signatory Contact No-912070003						





**District Level Water analysis
Laboratory**
Uttar Pradesh Jal Nigam (Rural), Kushinagar
Add. -Vill Parsauni Kala Near Water Tank Padrauna
KUSHINAGAR 274304



TC-17214

Report No DL/KSN/ JULY/07

Analysis Report

Date 30.07.2026

Page No

01

Customer Details

Name and Address B.B.K. ACADEMY VILL- GAZIPUR, TAMKUHIRAJ, KUSHINAGAR

Ref. Letter No & Date NA

Basic details of sample

District KUSHINAGAR Block TAMKUHIRAJ
Gram Panchayat GAZIPUR Village GAZIPUR
Habitation GAZIPUR Location NEAR HANUMAN MANDIR
Water Source R.O WATER SAMPLE Sample Id KSN_07
Quantity of Sample 1000ml Date of S.C. 27.07.2026
Receiving Date 27.07.2026 S. Collector ANKIT SINGH
Sample Depositor ANKIT SINGH
Analysis Start Date 30.07.2026

Analysis Completion Date 30.07.2026

Temperature- 25±3°C

Relative Humidity- 50±15%

Technical Data of Analysis

S. No.	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values As per BIS 10500:2012			Ref. Method of Analysis
			Unit	Acceptable Limit	Permissible Limit	
1	2	3		4	5	6
1	pH	7.2	...	6.5	8.5	IS 3025(Part 11): 2022
2	Turbidity (NTU)	0.98	NTU	1.0	5.0	IS 3025(Part 10): 2023
3	TDS (mg/l)	110.5	mg/l	500	2000	IS 3025(Part 16): 2023
4	Total Alkalinity (mg/l)	152	mg/l	200	600	IS 3025(Part 23): 2023
5	Total Hardness (mg/l)	120	mg/l	200	600	IS 3025(Part 21): 2023
6	Calcium (mg/l)	32	mg/l	75	200	IS 3025(Part 40): 2019
7	Magnesium (mg/l)	9.72	mg/l	30	100	IS 3025(Part 46): 2019
8	Chloride (mg/l)	24	mg/l	250	1000	IS 3025(Part 32): 2019
9	Odor	Agreeable		Agreeable/Not Agreeable	Agreeable/Not Agreeable	IS 3025(Part 5): 2018
10	Taste	Agreeable		Agreeable/Not Agreeable	Agreeable/Not Agreeable	IS 3025(Part 3): 2023

BDL- Below Detection Limit, NA- Not Analyzed.

** Parameter(s) above permissible limit are in bold digits.

Note

1. This Certificate refers only to the particular sample (s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract.
3. The test results reported in this certificate are valid at the time of under the stated conditions of measurements.
4. Sample will be stored up to 07 days (in case of non-perishable item only) from the date of issue of tests reports.
5. * Parameter Are Not NABL accredited

Mamish
Prepared by

chandan
Reviewed By

Email id- labkushinagar@gmail.com

Authorized Signatory

Contact No-913776083

